



ENERGY BEFORE & AFTER READINGS

Celec - Power Correction Unit

Client :-	Residence – Teatree Place Mt Anna	Readings AMPS			Total + % Diff
Date Installed	Before Install	A phase	B phase	C phase	% Diff
October 2011	Power Factor	0.90	0.92	0.93	*
	Kilo Watts	1.6	1.2	1.2	*
	Current (amps)	7	5	5	*
	After Install	A phase	B phase	C phase	% Diff
	Power Factor	0.98	0.99	0.99	8% improve
	Kilo Watts	1.2	0.7	0.7	36% reduction
	Current (amps)	5	3	3	36% reduction
Installers name :-					

AVERAGE % SAVE FOR THIS INSTALL IS – 26%